


# CERTIFICATE OF INSPECTION

INVOICE ADDRESS			INSPECTION LOCATION					
Tree top catering			Tree top catering					
			colwick Depot					
			Nottingham					
			6x trailers					

We certify that the Equipment set out below has this day been inspected and serviced in accordance with B.S. 5306 PART 3 and refilled when required to B.S. 6643 PART 1 and future amendments.

Quantity	Type	Cap	*N	*NR	*G	*FC	*R	*HT	*DT	*FI	*F	REPORTS AND RECOMMENDATIONS				
	Water	6LR										Removed from site fo further repairs/replace				
	Water	9LT										2x fire blankets condemned due to contamination				
	AFFF	1LT														
	AFFF	2LT										2x 6kg powder missing hoses				
	AFFF	6LT										both failed to charge				
	AFFF	9LT														
1	Dry Powder	1KG				X										
4	Dry Powder	2KG				X										
	Dry Powder	4KG										CORRECTIVE ACTION TAKEN		DATE	SIGN	
3	Dry Powder	6KG			X							New/refurb units on order		2.3.2012		
	Dry Powder	9KG														
	CO <sup>2</sup>	2KG														
	CO <sup>2</sup>	5KG														
	HOSE REELS															
2	FIRE BLANKETS					X					X					
	WET CHEM	3LT														
1	WET CHEM	6LT									X					
*CODE		G Good Condition	'FC Fair Condition			'R Refill			HT Hydraulic Test			*DT Discharge Test			FI' Factory Inspection	
F' Failed		N* New			NR; New Refurb			SC.No.ttc 13287614037291						Certificate No:		
Service Engineer's Signature:/name abarker					Customers Signature:						Date: 09/03/2011			1958973		