

# CERTIFICATE OF INSPECTION

INVOICE ADDRESS	INSPECTION LOCATION
Tree top catering	Tree top catering
	colwick Depot
	Nottingham
	<b>6x trailers</b>



## SITE-RESCUE

Protecting People, Site and Product

Jubilee House, Church Street,  
Morley, Leeds, LS27 9JQ

# 0845 094 2757

**We certify that the Equipment set out below has this day been inspected and serviced in accordance with B.S. 5306 PART 3 and refilled when required to B.S. 6643 PART 1 and future amendments.**

Quantity	Type	Cap	*N	*NR	*G	*FC	*R	*HT	*DT	*FI	*F	REPORTS AND RECOMMENDATIONS			
	Water	6LR										Removed from site fo further repairs/replace 2x fire blankets condemed due to contamination			
	Water	9LT													
	AFFF	1LT										2x 6kg powder missing hoses both failed to charge			
	AFFF	2LT													
	AFFF	6LT													
	AFFF	9LT													
1	Dry Powder	1KG				X									
4	Dry Powder	2KG				X									
	Dry Powder	4KG											<b>CORRECTIVE ACTION TAKEN</b>	<b>DATE</b>	<b>SIGN</b>
3	Dry Powder	6KG			X								New/refurb units on order	2.3.2012	
	Dry Powder	9KG													
	CO <sup>2</sup>	2KG													
	CO <sup>2</sup>	5KG													
	HOSE REELS														
2	FIRE BLANKETS					X					X				
	WET CHEM	3LT													
1	WET CHEM	6LT									X				
*CODE	G Good Condition	'FC Fair Condition	'R Refill	HT Hydraulic Test		*DT Discharge Test		FI' Factory Inspection							
F' Failed	N* New	NR; New Refurb		SC.No.ttc 13287614037291				Certificate No:							
Service Engineer's Signature:/name abarker			Customers Signature:					Date: 09/03/2011			1958973				