

**CERTIFICATE OF INSPECTION**

INVOICE ADDRESS	INSPECTION LOCATION
Tree top catering	Tree top catering
	colwick Depot
	Nottingham
	<b>6x trailers</b>



**SITE-RESCUE**  
Protecting People, Site and Product

Jubilee House, Church Street,  
Morley, Leeds, LS27 9JQ

**0845 094 2757**

We certify that the Equipment set out below has this day been inspected and serviced in accordance with B.S. 5306 PART 3 and refilled when required to B.S. 6643 PART 1 and future amendments.

Quantity	Type	Cap	*N	*NR	*G	*FC	*R	*HT	*DT	*FI	*F	REPORTS AND RECOMMENDATIONS	
	Water	6LR										Removed from site fo further repairs/replace 2x fire blankets condemed due to contamination	
	Water	9LT											
	AFFF	1LT											
	AFFF	2LT											2x 6kg powder missing hoses both failed to charge
	AFFF	6LT											
1	Dry Powder	1KG				X							
4	Dry Powder	2KG				X							
	Dry Powder	4KG										CORRECTIVE ACTION TAKEN	
3	Dry Powder	6KG			X								New/refurb units on order
	Dry Powder	9KG										DATE	
	CO <sup>2</sup>	2KG										SIGN	
	CO <sup>2</sup>	5KG											
	HOSE REELS												
2	FIRE BLANKETS					X					X		
	WET CHEM	3LT											
1	WET CHEM	6LT									X		
*CODE	G Good Condition	'FC Fair Condition	'R Refill	HT Hydraulic Test		*DT Discharge Test		FI' Factory Inspection					
F' Failed	N* New	NR; New Refurb		SC.No.ttc 13287614037291				Certificate No:					
Service Engineer's Signature:/name abarker			Customers Signature:				Date: 09/03/2011		1958973				