

H. OBSERVATIONS AND RECOMMENDATIONS FOR ACTION TO BE TAKEN

Referring to the attached schedules of inspection and test results, an subject to the limitations at E: There are no items adversely affecting electrical safety. or

The following observations and recommendations are made. N/A

Item No	Code †

† Where observations are made, the inspector will have entered one of the following codes against each observation to indicate the action (if any) recommended:
 1. 'requires urgent attention' or
 2. 'requires improvement' or
 3. 'requires further investigation' or
 4. 'does not comply with BS 7671'

Please see the reverse of this page for guidance regarding recommendations.
 Urgent remedial work recommended for items: 0
 Corrective action(s) recommended for items: 0

I. SUMMARY OF THE INSPECTION

General condition of the installation: GOOD

Note: If necessary, continue on additional page(s), which must be identified by the Transportable Building Periodic Inspection Report serial number and page numbers.
 Evidence of alterations: No If yes, estimated age: 4 years
 or additions: NOT AVAILABLE

Electrical Installation Certificate no. or previous Periodic Inspection Report no.:
 Date(s) of the inspection: 12-03-12 Date of previous inspection: N/A

Overall assessment of the installation: Satisfactory
 (Entry should read either 'Satisfactory' or 'Unsatisfactory')

J. NEXT INSPECTION

We recommend that this installation is further inspected and tested after an interval of not more than: 1 YEAR
 (Enter interval in terms of years or months, as appropriate)
 I/We recommend that any item at H which have been attributed a Recommendation Code 1 (requires urgent attention) and Code 2 (requires improvement) are remedied without delay and as soon as possible respectively. Items which have been attributed a Recommendation Code 3 should be actioned as soon as practicable (see H).

K. TRANSPORTABLE BUILDING PARAMETERS

Nominal voltage U ₀ /U:	230 V / 230 V	Nominal frequency:	50 Hz	Maximum load per phase provision:	40 Amps	Maximum tolerable fault current:	6 kA
No of Phases:	1	Acceptable system type(s):	TN-S TN-C-S TT	Maximum tolerable upstream earth fault loop impedance, Z _T :	3.08 Ω		

PARTICULARS OF TRANSPORTABLE BUILDING INSTALLATION

Nominal voltage(s) U (V) / U ₀ (V)	Number of phases	Type [BS (EN) ...]	Main equipotential bonding to extraneous-conductive-parts:	Main Switch Voltage rating (V)	Rated current, I _n (A)	Short-circuit capacity (kA)	Residual operating current I _{Δn}
230	230	1	61008 RCD	230	40	6	30
Protective measure(s) against electric shock: Main equipotential bonding to extraneous-conductive-parts: ADS Water supply connection: N/A Gas supply connection: N/A Oil supply connection: N/A Transportable building structural steelwork (if any): <input checked="" type="checkbox"/> Other: N/A							
Main protective bonding conductors: Material: COPPER csa (mm ²): 4							