

CERTIFICATE OF INSPECTION

INVOICE ADDRESS	INSPECTION LOCATION
Tree top catering	Tree top catering
	colwick Depot
	Nottingham
	6x trailers



SITE-RESCUE

Protecting People, Site and Product

Jubilee House, Church Street,
Morley, Leeds, LS27 9JQ

0845 094 2757

We certify that the Equipment set out below has this day been inspected and serviced in accordance with B.S. 5306 PART 3 and refilled when required to B.S. 6643 PART 1 and future amendments.

Quantity	Type	Cap	*N	*NR	*G	*FC	*R	*HT	*DT	*FI	*F	REPORTS AND RECOMMENDATIONS			
	Water	6LR										Removed from site fo further repairs/replace 2x fire blankets condemed due to contamination 2x 6kg powder missing hoses both failed to charge			
	Water	9LT													
	AFFF	1LT													
	AFFF	2LT													
	AFFF	6LT													
	AFFF	9LT													
1	Dry Powder	1KG				X									
4	Dry Powder	2KG				X									
	Dry Powder	4KG											CORRECTIVE ACTION TAKEN	DATE	SIGN
3	Dry Powder	6KG			X							New/refurb units on order	2.3.2012		
	Dry Powder	9KG													
	CO ²	2KG													
	CO ²	5KG													
	HOSE REELS														
2	FIRE BLANKETS					X					X				
	WET CHEM	3LT													
1	WET CHEM	6LT									X				
*CODE	G Good Condition	'FC Fair Condition	'R Refill		HT Hydraulic Test			*DT Discharge Test			FI' Factory Inspection				
F' Failed	N* New		NR; New Refurb			SC.No.ttc 13287614037291					Certificate No:				
Service Engineer's Signature:/name abarker					Customers Signature:					Date: 09/03/2011			1958973		