

CERTIFICATE OF INSPECTION

| INVOICE ADDRESS | INSPECTION LOCATION |
|-------------------|---------------------|
| Tree top catering | Tree top catering |
| | colwick Depot |
| | Nottingham |
| | |
| | |
| | 6x trailers |
| | |
| | |



SITE-RESCUE

Protecting People, Site and Product

Jubilee House, Church Street,
Morley, Leeds, LS27 9JQ

0845 094 2757

We certify that the Equipment set out below has this day been inspected and serviced in accordance with B.S. 5306 PART 3 and refilled when required to B.S. 6643 PART 1 and future amendments.

| Quantity | Type | Cap | *N | *NR | *G | *FC | *R | *HT | *DT | *FI | *F | REPORTS AND RECOMMENDATIONS | | | |
|---|------------------|--------------------|----------------|-----|-------------------------|--------------------------|----|--------------------|-----|---------------------|------------------------|--|---------|--|--|
| | Water | 6LR | | | | | | | | | | Removed from site fo further repairs/replace 2x fire blankets condemed due to contamination | | | |
| | Water | 9LT | | | | | | | | | | | | | |
| | AFFF | 1LT | | | | | | | | | | 2x 6kg powder missing hoses both failed to charge | | | |
| | AFFF | 2LT | | | | | | | | | | | | | |
| | AFFF | 6LT | | | | | | | | | | | | | |
| | AFFF | 9LT | | | | | | | | | | | | | |
| 1 | Dry Powder | 1KG | | | | X | | | | | | | | | |
| 4 | Dry Powder | 2KG | | | | X | | | | | | | | | |
| | Dry Powder | 4KG | | | | | | | | | | | | | |
| 3 | Dry Powder | 6KG | | | X | | | | | | | | | | |
| | Dry Powder | 9KG | | | | | | | | | | | | | |
| | CO ² | 2KG | | | | | | | | | | | | | |
| | CO ² | 5KG | | | | | | | | | | | | | |
| | HOSE REELS | | | | | | | | | | | | | | |
| 2 | FIRE BLANKETS | | | | | X | | | | | X | | | | |
| | WET CHEM | 3LT | | | | | | | | | | | | | |
| 1 | WET CHEM | 6LT | | | | | | | | | X | | | | |
| *CODE | G Good Condition | 'FC Fair Condition | 'R Refill | | HT Hydraulic Test | | | *DT Discharge Test | | | FI' Factory Inspection | | | | |
| F' Failed | N* New | | NR; New Refurb | | | SC.No.ttc 13287614037291 | | | | | Certificate No: | | | | |
| Service Engineer's Signature:/name abarker | | | | | Customers Signature: | | | | | Date: 09/03/2011 | | | 1958973 | | |